



2 1.
1
2 2.

3. Tees or Wyes less than 6' deep shall be laid flat.
4. Minimum depth of lateral at curb line and at property line to be determined in the field.
5. Where lateral is constructed under an existing curb, the contractor shall chisel the letter "L" into the curb face directly above the lateral. "L" to be 1 1/2" high and 3/16" deep.
6. Backfill over laterals to be compacted by tamping only.
7. For connection to mains less than 12" make connections Wye, Tee, or Saddle Tee.
8. For connection to mains 12" or larger make connections with cored hole and Saddle Tee.

APPROVED	DATE
PUBLIC WORKS DIRECTOR - R.C.E 18793	
CHANGED NOTE 1, ADDED NOTE 2, ABS & PVC OPT, 4" PIPE LABEL, ADDED NOTE 7, NOTE 8.	
DELETED NOTES 1 & 2.	
MARK	REVISIONS
APPR.	DATE

CITY OF RIVERSIDE
PUBLIC WORKS DEPT. - ENGINEERING DIV.

SEWER LATERAL

STANDARD DRAWING NO.

562